

STATE OF VERMONT
PUBLIC SERVICE BOARD

Docket No. 6636

Petition of Green Mountain Power Corporation)
and the Winooski Community Development)
Corporation for a certificate of public good for)
the relocation of approximately 1900 feet of)
34.5 kV transmission line No. 3307 located in)
Winooski and Burlington, Vermont)

Entered: 4/10/2002

CERTIFICATE OF PUBLIC GOOD ISSUED
PURSUANT TO 30 V.S.A. SECTION 248

IT IS HEREBY CERTIFIED that the Public Service Board of the State of Vermont this day found and adjudged that the replacement of approximately 1600 feet of existing overhead 34.5 kV transmission line with approximately 1900 feet of new underground 34.5 kV transmission line, located in the City of Winooski, Vermont, with a small portion located in the City of Burlington, Vermont, will promote the general good of the state, subject to the following conditions:

1. Construction, operation and maintenance of the project shall be in accordance with the plans and evidence submitted in this proceeding.
2. Green Mountain Power Corporation ("GMP") and the Winooski Community Development Corporation ("WCDC") shall obtain and comply with all conditions and requirements of all necessary permits and approvals.
3. GMP and WCDC shall construct and operate the relocated transmission line approved herein in conformance with all the terms and conditions of the Act 250 permit (Permit #4C1065(revised)) issued to WCDC and GMP.
4. GMP and WCDC shall dispose of all waste materials resulting from the line relocation at a state-approved landfill or disposal area.

5. With regard to the Class II wetland and associated buffer located at the eastern edge of the project area: (1) undergrounding of the transmission line within the Class II wetland buffer zone shall be accomplished using either "jack and bore" or "directional bore" methods; (2) GMP and WCDC shall place a snow fence or other equivalent structure along the perimeter of the Class II wetland buffer zone during construction of any adjacent structures or buildings to ensure that construction machinery is not operated within the buffer zone; and (3) GMP and WCDC shall remove any existing urban waste material located above ground-level (i.e. concrete, rebar, etc.) from the Class II buffer area. GMP and WCDC shall minimize disturbance of the buffer area during such removal, including the disturbance of existing vegetation.

6. Within 60 days after the date of this certificate, GMP shall file with the Board, for its review and approval, a plan for reclamation of the Chace Mill Substation site after removal of the existing facility.

7. This Certificate shall not be transferred without prior approval of the Board.

Dated at Montpelier, Vermont, this 10th day of April, 2002.

<u>s/Michael H. Dworkin</u>)	
)	PUBLIC SERVICE
)	
<u>s/David C. Coen</u>)	BOARD
)	
)	OF VERMONT
<u>s/John D. Burke</u>)	

OFFICE OF THE CLERK

FILED: April 10, 2002

ATTEST: s/Susan M. Hudson

Clerk of the Board

NOTICE TO READERS: This decision is subject to revision of technical errors. Readers are requested to notify the Clerk of the Board (by e-mail, telephone, or mail) of any apparent errors, in order that any necessary corrections may be made. (E-mail address: Clerk@psb.state.vt.us)