

STATE OF VERMONT  
PUBLIC SERVICE BOARD

Docket No. 7100-A

Amended Petition of Central Vermont Public Service )  
Corporation for a Certificate of Public Good )  
pursuant to 30 V.S.A. § 248(j) authorizing the year- )  
2001 replacement of a 2.5 MVA transformer at the )  
Mount Holly substation in Mount Holly, Vermont )  
with a 5 MVA transformer from the Bethel )  
substation located in Royalton, Vermont )

Entered: 6/5/2006

**CERTIFICATE OF PUBLIC GOOD ISSUED**  
**PURSUANT TO 30 V.S.A. SECTION 248**

IT IS HEREBY CERTIFIED that the Public Service Board of the State of Vermont this day found and adjudged that Central Vermont Public Service Corporation's year-2001 replacement of a 2.5 MVA transformer at the Mount Holly substation in Mount Holly, Vermont, with a 5 MVA transformer from the Bethel substation located in Royalton, Vermont, in accordance with the evidence and plans submitted in this proceeding, will promote the general good of the State, subject to the following conditions:

1. Operation and maintenance of the project shall be in accordance with the plans and evidence submitted in this proceeding.
2. Within two weeks of the date of issuance of the Certificate of Public Good, CVPS shall file a description of the disposal method for the PCB-containing oil from the 2.5 MVA transformer that was removed from the Mt. Holly substation, and for the PCB-containing oil from the 5 MVA transformer that was removed from the Bethel substation and relocated to the Mt. Holly substation.
3. This Certificate of Public Good shall not be transferred without prior approval of the Board.

DATED at Montpelier, Vermont, this 5<sup>th</sup> day of June, 2006.

<u>s/James Volz</u>	)	
	)	PUBLIC SERVICE
	)	
<u>s/David C. Coen</u>	)	BOARD
	)	
	)	OF VERMONT
<u>s/John D. Burke</u>	)	

OFFICE OF THE CLERK

FILED: June 5, 2006

ATTEST: s/Susan M. Hudson  
Clerk of the Board

*NOTICE TO READERS: This decision is subject to revision of technical errors. Readers are requested to notify the Clerk of the Board (by e-mail, telephone, or in writing) of any apparent errors, in order that any necessary corrections may be made. (E-mail address: Clerk@psb.state.vt.us)*

*Appeal of this decision to the Supreme Court of Vermont must be filed with the Clerk of the Board within thirty days. Appeal will not stay the effect of this Order, absent further Order by this Board or appropriate action by the Supreme Court of Vermont. Motions for reconsideration or stay, if any, must be filed with the Clerk of the Board within ten days of the date of this decision and order.*