

STATE OF VERMONT
PUBLIC SERVICE BOARD

CPG #NM-632

Application of Green Mountain College for a)
certificate of public good for an interconnected net)
metered biomass electrical power system)

Entered: 8/25/2009

CERTIFICATE OF PUBLIC GOOD ISSUED
PURSUANT TO 30 V.S.A. SECTION 248

IT IS HEREBY CERTIFIED that the Public Service Board of the State of Vermont ("Board") this day found and adjudged that the net metering system proposed by Green Mountain College to be located at One Brennan Circle in Poultney, Vermont, will promote the general good of the State, subject to the following conditions:

1. Operation, construction, and maintenance of the project shall be in accordance with the plans and evidence submitted in this proceeding. Any material or substantial change in the project is prohibited without prior Board approval.
2. The net metering system shall comply with applicable existing and future statutory requirements and Board Rules and Orders.
3. In the event this Certificate is transferred pursuant to Board Rule 5.100, Section 5.107(B)1, the new owner of the system must file the required certificate transfer form with the Board prior to commencing operation of the system.
4. The inrush current drawn by the system shall not exceed 83.7 amps at primary voltage.
5. Green Mountain College shall enter into a binding Operating Protocol with Central Vermont Public Service Corporation prior to interconnecting the system.
6. The system shall include a system shutdown switch that will be located proximate to the system disconnect switch.
7. Green Mountain College shall continue to provide protection scheme information and settings to Central Vermont Public Corporation for their review.

DATED at Montpelier, Vermont, this 25th day of August, 2009.

<u>s/James Volz</u>)	
)	PUBLIC SERVICE
)	
<u>s/David C. Coen</u>)	BOARD
)	
)	OF VERMONT
<u>s/John D. Burke</u>)	

OFFICE OF THE CLERK

Filed: August 25, 2009

Attest: s/Susan M. Hudson
Clerk of the Board

NOTICE TO READERS: This decision is subject to revision of technical errors. Readers are requested to notify the Clerk of the Board (by e-mail, telephone, or in writing) of any apparent errors, in order that any necessary corrections may be made. (E-mail address: psb.clerk@state.vt.us)