

STATE OF VERMONT
PUBLIC SERVICE BOARD

Docket No. 7515

Petition of Green Mountain Power Corporation for a)
certificate of public good authorizing the permanent)
installation of a bank of three single-phase)
transformers with a 14 MVA three-phase transformer)
at it's Westminster Substation #74, located on Back)
Westminster Road in the Town of Westminster,)
Vermont)

Entered: 7/10/2009

CERTIFICATE OF PUBLIC GOOD ISSUED
PURSUANT TO 30 V.S.A. SECTION 248

IT IS HEREBY CERTIFIED that the Public Service Board of the State of Vermont this day found and adjudged that the proposed permanent installation of a temporary three-phase 14 MVA transformer at the Westminster substation in Westminster, Vermont, in accordance with the evidence and plans submitted in this proceeding, will promote the general good of the State, subject to the following conditions:

1. The Project shall be constructed in accordance with the evidence and plans submitted in this proceeding.
2. Green Mountain Power Corporation ("GMP") shall notify the Public Service Board and the Department of Public Service once the Westminster substation feeders are converted to 12.47 kV. If the upgrade to the feeders does not occur prior to the summer of 2014, GMP must file an explanation as to why the feeder conversion has not taken place and how it intends to address back up of the Bellows Falls substation.
3. GMP shall confirm that the 14 MVA transformer will be dual voltage to allow for the upgrade of the Westminster feeders.
4. GMP shall file detailed plans for the oil-containment system prior to construction.
5. This Certificate of Public Good shall not be transferred without prior approval of the Board.

DATED at Montpelier, Vermont, this 10th day of July, 2009.

s/James Volz _____)

) PUBLIC SERVICE

s/David C. Coen _____)

) BOARD

s/John D. Burke _____)

) OF VERMONT

OFFICE OF THE CLERK

Filed: July 10, 2009

Attest: s/Judith C. Whitney
Deputy Clerk of the Board

NOTICE TO READERS: This decision is subject to revision of technical errors. Readers are requested to notify the Clerk of the Board (by e-mail, telephone, or in writing) of any apparent errors, in order that any necessary corrections may be made. (E-mail address: psb.clerk@state.vt.us)